

ANNEXURE - I

(Annexure to G.O. Ms.No. 56, Home (Ser. IV) Department, Dated: 26.07.2019)

Instructions to be followed for schools existing before 13.04.2009;

SELF CERTIFICATION FORM


Self Certification of Fire Safety Measures by School Management ;

i) General Information for School Buildings of all categories i.e., A, B, C & D.

Sl. No.	Details	
1	Date of the opening of the school building	01-06-2001
2	Name of the applicant	P. JYOTHI (CORRESPONDENT)
3	Name and address of the School	THE SECUNDERABAD PUBLIC SCHOOL
4	Telephone Number and email of the applicant	9246399386 / tsps.secbad@gmail.com
5	Height of the building (in meters)	10.10 mts
6	No of floors	G+2
7	Abutting Road width (in meters)	13.716
8	Built-up area of each floor in Sq.Mtrs Stilt ----- Ground 960.63 Floor1 960.63 Floor2 960.63	2881.89
9	Number of Staircases Staircase 1 --- 02:30 --- (width in meters) Staircase 2 --- 01:45 --- (width in meters)	03.75
10	Width of each Staircase	-
11	Open Spaces Front ----- 6:50 ----- (width in meters) i Side 1 ----- ----- (width in meters) g Side 2 ----- 10:00 ----- (width in meters) n Rear ----- ----- (width in meters) a	26.50


PRINCIPAL
The Secunderabad Public School



Signature with date of
School authority and Seal
For THE SECUNDERABAD PUBLIC SCHOOL

(P. Jyothi)
Secretary/Correspondent


B) School Buildings with Ground plus two floors and less than 15 Meters in height.

Sl. No	Fire equipment required	Scale of fire equipment as per Norms	Required	Provided
				Yes/No
1	Fire Extinguishers (IS 2190:2010)	Two 09 liters water expelling extinguishers or ABC 4 kgs fire extinguisher, for every 200 square meters with minimum of 04 extinguishers per compartment/floor. The extinguisher should be so located as to be available within 15 meter radius.		YES
2	First Aid Hose Reel (IS 884:1985)	1 No for every 1000 square meter		YES
3	Terrace Tank over respective tower terrace	10000 Liters (5000 Liters additionally shall be provided if basement exceeds 200 square meters)		YES
4	Automatic Sprinkler System (IS 15105:2002) The IS standard may be downloaded from www.https://bis.gov.in/	To be installed in basement. If area of basement exceeds 200 square meters		YES
5	Pump capacity in LPM at the terrace tank level with minimum pressure of 3.5 kg/cm ²	450 LPM (450 LPM additionally shall be provided if basement exceeds 200 square meters)		YES
Additional Fire Safety Measures in lieu of deficiency in Setbacks.				
1	Water Shower curtain	Water Shower curtain shall be provided in all floors on the side/sides having deficiency of setback to overcome exposure hazard from fires from neighboring property.		NO
2	Fire Brigade inlet	02 Nos		YES

Note: If the floor area in a single floor more than 500 square meters and if there is only single stair case, a second stair case of 1.5 Meters width shall be provided with concrete/Metal steel structure.


PRINCIPAL
 The Secunderabad Public School



Signature with date and Seal
 for THE SECUNDERABAD PUBLIC SCHOOL
 School authority and Seal

(P. Jyothi)
 Secretary/Correspondent



From:

The Commissioner,
Greater Hyderabad Municipal
Corporation, Hyderabad.

To:

District Educational Officer,
Hyderabad District.

Rc.No: 22/AD/FPW/GHMC/2013, Dated: 10-01-2013

Sir,

SUB: Greater Hyderabad Municipal Corporation - Fire Prevention Wing - Non-Multi Storied Building of Secunderabad Public School, D.No: 2-12-70, West Marredpally, Secunderabad - Issuance of Fire No Objection Certificate - Regarding.

REF: 1. Lr.Rc.No: 27/FPW/AD/HO/2009 of the Commissioner, GHMC, Hyderabad.
2. Letter Rc.No: 5041/B2/97 of Director General, A.P Disaster Response & Fire Services Department, Dated: 12-03-2010.
3. Application No: Nil, Dated: 05-01-2013, Correspondent C/o. Secunderabad Public School, West Marredpally, Secunderabad.

*** *****

Under the powers delegated vide reference 1st & 2nd Cited, the inspection committee has inspected the existing Non Multi Storied School building premises of Secunderabad Public School, D.No:2-12-70, West Marredpally, Secunderabad on 10-01-2013 and submitted the following report.

2) The Non Multi Storied building consisting of Ground + Two Floors with a height of 09.00 Mtrs for School, office & Nursery Block for [Educational Occupancy (School)]. The Management has submitted application for issuance of Fire No Objection Certificate for Existing buildings.

3) a) PARTICULARS OF THE BUILDING:-

a)	Address of the building	SECUNDERABAD PUBLIC SCHOOL, D.NO: 2-12-70, WEST MARREDPALLY, SECUNDERABAD	
b)	Built-up area / height of the building	SCHOOL BLOCK 2072.76 Sq. Mtrs/09.00 Mtrs	OFFICE & NURSERY BLOCK 809.13 Sq. Mtrs/09.00 Mtrs
c)	No of blocks / floors	Two	
		G + 2	G + 2
d)	Type of occupancy	Educational Building (B)	

b) FLOOR WISE DETAILS:

Sl. No	Floor	Area in Sq. Meters.		Occupancy (Educational/ Hostel)		Occupant Load as given the management	
		S/BLOCK	O/N BLOCK	S/BLOCK	O/N BLOCK	S/BLOCK	O/N BLOCK
1.	Ground Floor	690.92	269.71	Edn	Edn	180	70 & office
2.	First Floor	690.92	269.71	Edn	Edn	180	70 & Hall
3.	Second Floor	690.92	269.71	Edn	Edn	180	
	Total	2072.76	809.13			540	210

4) MEANS OF ESCAPE:

SCHOOL BLOCK: The builder has provided Two Internal staircases with a width of 02.30 & 01.45 meters respectively. The occupant Load as per area is $690.92/4 = 172.73$ Nos. and exit width required is $180/25 = 07.20$ units of 0.50 meters i.e. 03.60 meters & aggregate exit width provided is 03.75 meters.

OFFICE & NURSERY BLOCK: The builder has provided One Internal staircase with a width of 01.50 meters. The occupant Load as per area is $269.71/4 = 67.4275$ Nos. and exit width required is $70/25 = 02.80$ units of 0.50 meters i.e. 01.40 meters & aggregate exit width provided is 01.50 meters.

5) OPEN SPACES ALL ROUND BUILDING ARE:-

	Open space to be provided as per the G.O. Ms. No. 168, Dated : 07-04-2012 MAUD(M) Dept, Section -7.1 in Table -III	Open spaces provided by the builder.		Deficit	
		S/BLOCK	O/N BLOCK	S/BLOCK	O/N BLOCK
Front	03.00 Mtrs.	12.00 M	12.00 M	Nil (Road)	Nil (Road)
Side-1	03.50 Mtrs.	03.00 M	01.00 M	03.00 M	05.00 M
Side-2	03.50 Mtrs.	03.00 M	02.00 M	03.00 M	04.00 M
Rear	03.50 Mtrs.	03.00 M	03.00 M	03.00 M	03.00 M

5) Strict compliance with all fire safety provision as per the conditions of **FIRE NO OBJECTION CERTIFICATE** issued vide Part 4 National Building code of India and of Building rules, particularly the following should be ensured at all time.

- 1 Fixed and first-aid Fire Fighting equipment, alarm etc shall be tested and maintained regularly as per applicable standards and Fire-Drills conducted quarterly for first two years and three after half yearly.
- 2 No temporary structure such as tents or with thatched construction should be allowed for educational institutions.
- 3 Emergency power generator etc., and associated equipment it feeds, should be periodically, verified as per NBC, and IS-1646.
- 4 Every room with a capacity of 45 students shall be maintained obstruction free minimum two doorways.
- 5 Every vertical opening between at the floors shall be suitably enclosed or protected, with ventilation System by ducts and Balconies.
- 6 The Builder / Occupier should facilitate periodical inspection by jurisdiction Station Fire Officer and District Fire Officer, Fire Prevention Wing, GHMC, Hyderabad.

Sl. No.	Fire Safety Measures	Required as Per Table 23 of NBC of India 2005	Provided		Deficiencies
			S/BLOCK	O/N BLOCK	
1.	Fire Buckets with Dry Sand	Required	Provided	Provided	Nil
2.	ABC Type Fire Extinguisher of 05 K.G Capacity	Required	Provided	Provided	Nil
3.	Hose Reel	Required	Provided	Provided	Nil
4.	Down Comer	Required	Provided	Provided	Nil
5.	Booster Pump 900 LPM	Required	Provided	Provided	Nil
6.	Terrace Tank	Required	20,000 Ltrs		Nil
7.	Under Ground Tank	Required	10,000 Ltrs		Nil
8.	MOEAS with Hooters	Required	Provided	Provided	Nil

6) In View of the above, **FIRE NO OBJECTION CERTIFICATE** from the fire safety point of view is issued subject to the following Conditions.

1. The NOC issued is confined to the Fire Safety measures installed in the building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use / Occupancy or Building Regularization. The Owner / Occupier shall comply the Building Rules /Govt Orders as applicable
2. Evacuation plan at showing exit routes and recommended action plan be displayed at conspicuous locations and shall be exhibited all times, all escape /exit routes shall not be blocked or encroached.
3. Fresh NOC would be required for any change in occupancy or additions/alterations in the building structure as per NBC of India and building bye/laws.
The Management has to maintain Fire Safety Measures at all times in good working Condition as seen during the inspection.
5. Any Loss of life or property due to Non - functioning of Fire Safety Measures and other installations shall be the responsibility of the management/owner.
6. All the Occupants must know the correct method of operation of the Fire Fighting System installed.
7. All Occupants/ security personnel shall be trained to operate the Fire Safety Equipment during the Emergency.
8. Additional/ Alteration, if any, in the building may be verified by building authority.
9. The Fire Drills Shall be conducted once in every Six months for initial two years, thereafter, once in every 6 months.

10) **FIRE NO OBJECTION CERTIFICATE** is valid for one year from the date of issue. It is the responsibility of the builder / Occupier to apply for renewal of Fire NOC, one month before expiry of this Fire NOC.

For PEOPLES EDUCATIONAL ACADEMY



[Signature]
PRINCIPAL
The Secunderabad Public School

[Signature]
COMMISSIONER
GHMC, HYDERABAD
23/11/13

Copies to:

- 1) Correspondent C/o. Secunderabad Public School, West Marredpally, Secunderabad.
- 2) The Chief City Planner, GHMC, Hyd.